



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 29 Aug 2022

HEIDI SOLBERG
 IEA/BROOKLYN PARK
 9201 W BDWY STE #600
 BROOKLYN PARK MN 55445

Work Order #: 12-14702
 Account #: 002190
 Purchase Order #: 202210856

Date Received: 23 Aug 2022
 Date Sampled: 19 Aug 2022
 Time Sampled: 10:00
 Temperature at Receipt: AMBIENT

PROJECT NAME: DISCOVERY
 PROJECT NUMBER: 202210856

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
22-A44136	081922-01-SL 2ND FLOOR	2.61 ug/L	15.0	26 Aug 22	KAM
22-A44137	081922-02-SL 3RD FLOOR LFT	3.63 ug/L	15.0	26 Aug 22	KAM
22-A44138	081922-03-SL 3RD FLOOR RT	8.47 ug/L	15.0	26 Aug 22	KAM

Approved by:

Dan O'Connell David Smahel
 Chemistry Laboratory Managers New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
 ! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.